



855 Mill Street, Suite 2B, Reno, NV 89502 | Phone: 775.750.0190 | Fax: 866.755.7619
 NV Laboratory ID: NV00923 | NY Laboratory ID: 11900 | EPA Laboratory ID: NV00923

NAS Laboratory Number:

Client Information

Contact: Mr. Smith
 Company/Client: Mr. Smith
 Address: 1000 Park Place Dr.
 City: Anywhere
 State: NV
 Zip: 10101
 Phone: 775-777-7777
 Fax: 775-777-7777

Sample Information

Identification: Kitchen Sink
 Matrix: Aqueous
 Sampling Date: 7/7/2008
 Submission Date: 7/7/2008
 Sampled By: Client
 Project: N/A
 Sampling Site: 7777 Park Place Dr.
 PO Number: N/A
 Reference Number: N/A

Constituent	Results (mg/L)		Acceptable Limits	Lab Use Only		
				Method	Date Analyzed	Balance
pH (SIU)	7.29	PASS	6.50 - 8.50	SM4500	7/7/2008	
EC (umhos/cm)	120		~	SM2510	7/7/2008	
Color (cu)	5		~	SM2120	7/7/2008	
Turbidity (NTU)	<0.5		~	SM2130	7/7/2008	
Carbonate	0.00		~	SM2310B	7/7/2008	0.00
Bicarbonate	57.3		~	SM2310B	7/7/2008	0.94
Fluoride	0.26	PASS	4.0	SM4500	7/7/2008	0.01
Chloride	0.35	PASS	400	SM4500	7/7/2008	0.01
Nitrate as Nitrogen	<0.50	PASS	10.0	SM4500	7/7/2008	0.00
Nitrite as Nitrogen	<0.05	PASS	1.00		7/7/2008	
Sulfate	3.87	PASS	500	SM4500	7/7/2008	0.08
Silica	2.75		~	SM3120B	7/7/2008	0.05
						1.09
Sodium	14.9		~	SM3120B	7/7/2008	0.65
Potassium	2.76		~	SM3120B	7/7/2008	0.07
Calcium	3.78		~	SM3120B	7/7/2008	0.19
Magnesium	1.54	PASS	150	SM3120B	7/7/2008	0.13
						1.04
Hardness (as CaCO3)	15.8		~	Calculated	7/7/2008	
TDS (calc)	87.6	PASS	1000	SM2540C	7/7/2008	
Alkalinity (as CaCO3)	47.0		~	SM2310B	7/7/2008	
Arsenic	<0.01	PASS	0.01	SM3120B	7/7/2008	
Barium	<0.05	PASS	2.00	SM3120B	7/7/2008	
Copper	<0.05	PASS	1.00	SM3120B	7/7/2008	
Iron	0.12	PASS	0.60	SM3120B	7/7/2008	
Manganese	0.07	PASS	0.10	SM3120B	7/7/2008	
Zinc	1.57	PASS	5.00	SM3120B	7/7/2008	
Boron	0.45		~	SM3120B	7/7/2008	
Lead	<0.010	PASS	0.015	SM3120B	7/7/2008	
Microbiology (Present / Absent)						
Total Coliform	ABSENT	PASS	~	SM9221B	7/7/2008	Meq Ratio
E. Coli	ABSENT	PASS	~	SM9221B	7/7/2008	1.0254

*Notes:

mg/L = ppm (part per million)

Michael R. Genova, Technical Director

7/10/2008
 Date

Your water meets EPA primary and secondary drinking water standards unless otherwise noted.